

## **CLARIFICATIONS**

With reference to the subjected Tender (Reference No: SNDB/COK/ADMIN/TD/865/2017), following are the queries that need to be clarified,

1. In clause 2.65 Eligibility Criteria (point # 07: Direct Importer/Manufacturing Capacity minimum 4MW PV), kindly elaborate which type of relevant documents required to fulfil this requirement.

**Ans: 4 MW of Raw Material Goods' Declaration from Custom or proof of complete product import i.e. Solar, panels & cells.**

2. In mandatory requirement PEC with ME04 code is mentioned which is for Building Automation System i.e. not necessary for solar system, instead of this ME06 Code should be mentioned which is for specialized fabrication Please change accordingly.

**Ans: Please proceed as asked.**

3. In specifications of Mounting SS304 Material is required with 20 years warranty, SS304 will be expensive. Please confirm?

**Ans: Please proceed as asked.**

4. In specifications of Solar Inverters kindly mention which inverter you required for your system either European or Chinese because both have a different impact on system's Life. Further European inverters are more expensive than Chinese and long life (warranty) like Vise.

**Ans: The requirement is of 10 KW - on/ off grid and hybrid all in one inverter, with two years replacement warranty within 48 Hours.**

5. In financial Proposal transportation charges will be paid per 50km as mentioned, but it is better to use the transportation per branch.

**Ans: Please proceed as asked.**

6. Please confirm that when the performance security equals to 10% of the contract will be returned?

**Ans: After completion of two years of work.**

7. Kindly mention the DOD in battery size calculation, or it is already included in mentioned sizing. Please explain.

**Ans: Calculation will be based on 50% DOD.**